

Certificate

No. c6652a-21

Customer:

Ma-Fia s.r.o.
Scheinerova 65
628 00 Brno, Czech republic

Class E

Test sample(s):

Data Cable:
WIREX Installation Cable CAT6 U/UTP LSOH / DCA 500m reel violet
Part-no : WIC-6-U-LD-50-VI

Outlet:

WIREX Keystone CAT6 UTP toolless black
Part-no.: WKE-6-U-TL-BL

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

2 Connector Permanent Link, Copper, Class E

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **R6652a-21** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of testing.

Bexbach, 30.06.2021



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG

In der Kolling 320
66450 Bexbach / Germany

P0 box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de